

BS750 Underground fire Hydrant

SPECIFICATIONS

Size	DN 80
Class	PN 16
Design	BS 750
End Flange	BS 4504 / BS EN 1092
Test	BS 750

STANDARD MATERIALS OF MAIN PARTS

ITEM	PART NAME	MATERIAL
1	Body	Ductile Iron
2	Disc	Ductile Iron+NBR
3	Bonnet	Ductile Iron
4	Stem	Stainless Steel 420
5	Stem Nut	Brass
6	Holding Ring	Brass
7	Sealing Nut	Brass
8	Disc Ring	EPDM
9	Cap	Ductile Iron
10	Bonnet Gasket	NBR
11	O Ring	NBR
12	Dust Ring	NBR

